

鍋爐管、熱交換器、冷凝器管標準規格表

鍋爐管				
JIS日本		外徑(m m)	厚度(m m)	厚度(吋)
G3461	STB340	50.8	3.2	0.126
			4.0	0.157
			5.0	0.197
		63.5	3.2	0.126
			4.5	0.177
			5.0	0.197
		76.2	3.5	0.138
			4.0	0.157
			5.0	0.197
		88.9	3.5	0.138
			4.0	0.157
			5.0	0.197
		101.6	3.5	0.138
			4.0	0.157
		114.3	3.5	0.138
			4.0	0.157
			5.0	0.197
		熱交換器、冷凝器管		
ASTM	A179	19.05	2.11	0.083
			2.77	0.109
		25.4	2.11	0.083
			2.77	0.109